

# South Central Local Environmental Protection Group

Harper, Kingman and Kiowa County Sanitarian – Kyle W. Clark

P.O. Box 406 / 700 N. LL&G Anthony, KS 67003

Phone: (620)842-6000 Fax: (620)842-6002 Mobile: (620)243-3211

## County Horizontal Separation Distances

Per Harper, Kingman and Kiowa County Sanitation Code and KDHE Bulletin 4-2, March 1997

### Water Well To :

Septic Tanks Not 4-2 Approved	100 Feet
Sewer Lines Not Watertight	100 Feet
Absorption Fields	100 Feet
Pit Privies	100 Feet
Animal Pens or Manure Piles	100 Feet
Public Water Supply Wells	100 Feet
Water Tight Sewer Lines	50 Feet
Fertilizer, Fuel, Pesticides, other Chemical Storage	50 Feet
Surface Water, Streams, Lakes, and Drainage areas	50 Feet
Potential Pollution Sources or Contamination or as Determined by Sanitarian	50 Feet
Property Lines	25 Feet

### Waste Water Systems:

Public Sewage System Connection	400 Feet
Property Lines	50 Feet
Surface Water or Drainage Area	50 Feet
Septic Tank to Building Foundation	10 Feet
Soil Absorption Area to Building Foundation	20 Feet

### Wastewater Lagoons:

Water Wells	100 Feet
Property Lines	50 Feet
Dwelling Foundation	50 Feet

### Lot Size Requirements: (excluding buildings and structures)

Soil Absorption System	1 Acre
Water Wells	1 Acre
Wastewater Lagoon	3 Acres

**Note:** Local Zoning Regulations May Require Greater Separation Distances or Lot Sizes.

When lot dimension, topography, or soil condition makes maintaining the separation distances unfeasible a written easement from affected property owners shall be filed with the deeds office.